

Inspection Records for Permit Number A2013-000831**Job Address: 11619 W OXNARD ST****APN: 2338007015****Inspection Record Number 1**

Inspection Date:	06/11/2013
Inspector:	David Galvan
Inspection Type:	PRELIMINARY
Inspection Hours:	1.0
Record Date:	06/14/2013
Record Entered By:	David Galvan
Inspection Comments:	The `Q` section of the existing ADA ramp will need R&R to correct 12~ grooves, also will require truncated domes.

Inspection Record Number 2

Inspection Date:	06/20/2013
Inspector:	TERRY GORMAN
Inspection Type:	PRELIMINARY
Inspection Hours:	1.0
Record Date:	06/24/2013
Record Entered By:	TERRY GORMAN

Inspection Comments:	Form check for driveway apron and sidewalk only. Instructed contractor to re-cut @ the flowline for driveway forms, OK to place concrete. ADA ramp will be constructed at a later date. T.Gorman
-----------------------------	--

Inspection Record Number 3

Inspection Date:	06/26/2013
Inspector:	TERRY GORMAN
Inspection Type:	PRELIMINARY
Inspection Hours:	1.0
Record Date:	06/26/2013
Record Entered By:	TERRY GORMAN
Inspection Comments:	Inspection of ADA ramp removals in progress, and inspection of concrete driveway approach,sidewalk, contractor installed deep grooves against precon instructions. Contractor directed to fill grooves with sicaflex caulking or remove and replace work. Advised contractor installation of ADA truncated domes to be installed by certified person. T.Gorman

Inspection Record Number 4

Inspection Date:	07/16/2013
Inspector:	David Galvan
Inspection Type:	PRELIMINARY
Inspection Hours:	1.0
Record Date:	07/16/2013

Record Entered By:	David Galvan
Inspection Comments:	Onsite for final, the ADA ramp does meet requirements, however the certificate for the installer of the truncated domes panel was not verified, also the inspection of the new dwy was incomplete due to a pile of base obstructing a large portion of the dwy. Will need to reschedule.

Inspection Record Number 5

Inspection Date:	08/22/2013
Inspector:	TERRY GORMAN
Inspection Type:	FINAL
Inspection Hours:	1.0
Record Date:	08/22/2013
Record Entered By:	TERRY GORMAN
Inspection Comments:	Obstructions on driveway apron and ADA ramp were removed for inspection and accepted as final. T.Gorman

